

# INSPECTION REPORTS

# REPORT PROCESSING

- We continue to process both electronic and paper inspection reports.
- EDI = Electronic Data Interface. Method insurance companies send file to state.
- PV Main = Original Oracle application.
- PVERA = New web based Oracle application.
- PVERA to replace PV Main by July 1, 2015.

# REPORT PROCESSING

- Processed in 2014:
- 30,311 (56.2%) reports electronically through EDI.
- 14,538 (27.0%) reports electronically through PVERA.
- 9,085 (16.8%) paper reports.
- 53,934 total reports.

# REPORT PROCESSING

- EDI Report Errors:
- 30,611 reports submitted in text file.
- 26,648 (87.0%) processed immediately.
- 3,963 (1.3%) required review.
- 3,208 (10.5%) accepted after review.
- 755 (2.5%) were rejected and returned.
- All first inspections require review.

# COMMON REJECTIONS

- STATE # NOT IN ORACLE OR MICROFILM. CONFIRM & RESUBMIT.
- STATE AND NB #'S NOT IN ORACLE OR MICROFILM. CONFIRM & RESUBMIT.
- STATE # NOT IN ORACLE. CAN'T MAKE INACTIVE.
- STATE AND NB #'S NOT IN ORACLE. CAN'T MAKE INACTIVE.

# COMMON REJECTIONS

- NOT A CA STATE #. RESUBMIT.
- DUPLICATE STATE #. SEE YOUR INSPECTION DATED \_\_\_\_.
- NB#, YEAR, MFG, MAWP AND LOCATION DON'T MATCH DATABASE. CONFIRM & RESUBMIT.
- OUR RECORDS SHOW STATE # \_\_\_\_ FOR THIS NB # AND LOCATION. CONFIRM & RESUBMIT.

# COMMON REJECTIONS

- NO NB# PROVIDED. RESUBMIT.
- OUR RECORDS SHOW \_\_\_\_ PSI MAWP.  
CONFIRM & RESUBMIT.
- INCORRECT COUNTY CODE. RESUBMIT.
- INCORRECT PERMIT EXPIRE DATE. RESUBMIT.
- NO UT READINGS PROVIDED. RESUBMIT.
- LOCATION IN PLANT NOT PROVIDED.  
RESUBMIT.

# COMMON REJECTIONS

- MUST SUPPLY HEAD & SHELL THICKNESS.  
RESUBMIT.
- BILL TO INFORMATION INCOMPLETE.  
RESUBMIT.
- NO COMPANY NAME PROVIDED FOR USER.  
RESUBMIT.
- CONFIRM COMPLIANCE WITH (REQMNT?) &  
RESUBMIT.

# COMMON REJECTIONS

- CONTACT PV UNIT OFFICE FOR UNSAFE CONDITIONS AND CONFIRM COMPLIANCE.
- VERIFY CORRECT COUNTY CODE AND RESUBMIT.
- WE SHOW THIS AS COUNTY 81. CONFIRM & RESUBMIT.
- REPORT NOT IN INACTIVE FORMAT. RESUBMIT.
- WRONG EMPLOYER FOR INSPECTOR. REQUEST A NEW CERTIFICATE OF COMPETENCY.

# COMMON ERRORS

- When entering a condition comment, do not hit the computer “enter” key. This inserts a space into your comment and makes it hard to read.
- Coding a vessel to county 81 vs. 80. No permit is issued for county 81.
- Program releases all previous permits if change is made from 81 to 80.
- Confirm State or NB corrections on report.

# ISSUING PERMITS

- Pre-1996 objects are also in our microfilm database.
- De-rating air tanks need calculation and notation on inspection report.
- Can't issue permit if there are outstanding unsafe conditions.

# PERMIT PRESSURE

- Boiler pressure on permit should be the safety valve setting.
- Air & LPG tank pressure on permit is the stamped nameplate pressure.
- Exception: Air tanks that have plastic pipe are limited to 150psi.

# TEMPORARY BOILER PERMITS

- When repairs or replacements are required, the Division may grant the issuance of 30 day temporary permits.
- Make written request and receive written response.
- Inspector must submit an external inspection with a 30 day permit.

# NON-ASME TANKS

- If an air tank is non-ASME Code stamped, DO NOT put a state number on tank.
- A stamped state number indicates that it was acceptable at one time.
- Use your own companies policy on having the tank removed from service.

# STATE NUMBER

- How to handle 2017?
- -2017, -017, -17?
- Computer program needs expansion.